

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
01 - Forgan Smith	Level 1	Use after-hours pushbutton to start Air Conditioning	*Rooms booked via syllabus plus are exempt E107, 109, 112
01 - Forgan Smith	Level 2	Use after-hours pushbutton to start Air Conditioning	*Rooms booked via syllabus plus are exempt E212,E215,E219,E232, W247 *Rooms E225 and E227 are exempt *Law Library exempt
01 - Forgan Smith	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms booked via syllabus plus are exempt E301,E302,E303,E348,E356, W349,W332 *Law Library exempt *Comms rooms exempt (W305, W337)
01 - Forgan Smith	Level 4	Use after-hours pushbutton to start Air Conditioning	*Rooms booked via syllabus plus are exempt W426, W431, W458 *Law Library exempt
01 - Forgan Smith	Level 5	Use after-hours pushbutton to start Air Conditioning	
01 - Forgan Smith	Level 6	Use after-hours pushbutton to start Air Conditioning	
02 - Duhig Tower	Level 1	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
02 - Duhig Tower	Level 2	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
02 - Duhig Tower	Level 3	Use after-hours pushbutton to start Air Conditioning	*Office Areas only. Fryer Library Storage Exempt
02 - Duhig Tower	Level 4	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
02 - Duhig Tower	Level 5	Use after-hours pushbutton to start Air Conditioning	*Office Areas only. Fryer Library Storage Exempt
02 - Duhig Tower	Level 6	Use after-hours pushbutton to start Air Conditioning	*Office Areas only. Fryer Library Storage Exempt
02 - Duhig Tower	Level 7	Use after-hours pushbutton to start Air Conditioning	*Office Areas only. Fryer Library Storage Exempt
02 - Duhig Tower	Level 8	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
03 - Steele	Level 1	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
03 - Steele	Level 2	Use after-hours pushbutton to start Air Conditioning	*Rooms booked via syllabus plus are exempt 206, 232 *Theatre, Rock Labs, Earth Sciences, Comms room, Museum, are exempt *Rooms 221, 222, 228, 229 are exempt
03 - Steele	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms booked via syllabus plus are exempt 309, 315, 320, 329 *Rooms 314, 316, 319, 321-323, 329, 332-334, 336, 339-357, are exempt *Rooms 301-310 are exempt from Summer Holiday scheduling
05 - Richards	Level 1	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
05 - Richards	Level 2	Use after-hours pushbutton to start Air Conditioning	*Rooms 201-206, 209-212, 217, 218 are exempt

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
06 - Physics Annexe	Level 1	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
06 - Physics Annexe	Level 2	Use after-hours pushbutton to start Air Conditioning	*Server room exempt
06 - Physics Annexe	Level 3	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
06 - Physics Annexe	Level 4	Use after-hours pushbutton to start Air Conditioning	*Rooms 401-415, 421-499 exempt
06 - Physics Annexe	Level 5	Use after-hours pushbutton to start Air Conditioning	*Data room 516 exempt
07 - Parnell	Level 1	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only rooms 123 & 126 scheduled *workshop space exempt
07 - Parnell	Level 2	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
07 - Parnell	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms 303-309, 311, 313-322, 325, 327-396 exempt
08 - Goddard	Level 1	Normal Air Conditioning	*Room 139 booked via syllabus plus can be scheduled as normal
08 - Goddard	Level 2	Normal Air Conditioning	*Room 212 booked via syllabus plus can be scheduled as normal
08 - Goddard	Level 3	Normal Air Conditioning	*Room 388 booked via syllabus plus can be scheduled as normal
08 - Goddard	Level 4	Use after-hours pushbutton to start Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
08 - Goddard	Level 5	Use after-hours pushbutton to start Air Conditioning	*Room 544A exempt
09 - Michie	Level 1	24 Hour Operation	*All rooms on this floor are exempt from holiday scheduling
09 - Michie	Level 2	Use after-hours pushbutton to start Air Conditioning	*Central teaching rooms 201, 210, 211, 216-222 and the museum are exempt
09 - Michie	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms 314-324 are exempt
09 - Michie	Level 4	Use after-hours pushbutton to start Air Conditioning	*Open plan spaces are started by motion detectors on this floor
09 - Michie	Level 5	Use after-hours pushbutton to start Air Conditioning	*Central rooms 501, 536 exempt
09 - Michie	Level 6	Use after-hours pushbutton to start Air Conditioning	*Central rooms 601 exempt
09 - Michie	Level 7	Use after-hours pushbutton to start Air Conditioning	*Central rooms 701, 740 exempt *Offices 704-718 exempt from Summer Holidays scheduling only *Comms room exempt
09 - Michie	Level 8	Use after-hours pushbutton to start Air Conditioning	*Central rooms 801, 803, 836 exempt
11 - Mayne Centre	Level 1	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
11 - Mayne Centre	Level 2	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
11 - Mayne Centre	Level 3	Normal Air Conditioning	*Office area only - rooms 301-309, 393-399 exempt

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
14 - Sir Llew Edwards	Level 1	Use after-hours pushbutton to start Air Conditioning	*Central Rooms 115, 116, 132 exempt
14 - Sir Llew Edwards	Level 2	Use after-hours pushbutton to start Air Conditioning	*Central Rooms 212, 216, 217, 219 exempt
14 - Sir Llew Edwards	Level 3	Use after-hours pushbutton to start Air Conditioning	
14 - Sir Llew Edwards	Level 4	Use after-hours pushbutton to start Air Conditioning	
14 - Sir Llew Edwards	Level 5	Use after-hours pushbutton to start Air Conditioning	
14 - Sir Llew Edwards	Level 6	Use after-hours pushbutton to start Air Conditioning	
17 - Learning Innovation	Level 1	Use after-hours pushbutton to start Air Conditioning	
17 - Learning Innovation	Level 2	Use after-hours pushbutton to start Air Conditioning	
17 - Learning Innovation	Level 3	Use after-hours pushbutton to start Air Conditioning	
17 - Learning Innovation	Level 4	Use after-hours pushbutton to start Air Conditioning	
20 - Global Change Institute	All Levels	Use local touch screen control	
21C - Student Union	Level 1	Normal Air Conditioning	
21C - Student Union	Level 2	Use after-hours pushbutton to start Air Conditioning	*Only rooms 224, 226, 228 scheduled - all other areas on normal air conditioning
21C - Student Union	Level 3	Normal Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
21C - Student Union	Level 4	Normal Air Conditioning	
22 - Schonell Theatre	Theatres	No Air Conditioning	*Rooms booked via syllabus plus are exempt 201
23 - Abel Smith	Level 1	Use after-hours pushbutton to start Air Conditioning	*Room 101 booked via syllabus plus can be scheduled as normal
24 - Social Sciences	Level 2	No Air Conditioning	*Room 202 exempt
24 - Social Sciences	Level 3	Use after-hours pushbutton to start Air Conditioning	*Room 304 booked via syllabus plus can be scheduled as normal
24 - Social Sciences	Level 4	Use after-hours pushbutton to start Air Conditioning	*Room 402 booked via syllabus plus can be scheduled as normal
24 - Social Sciences	Level 5	Use after-hours pushbutton to start Air Conditioning	*Rooms S505 is exempt
24 - Social Sciences	Level 6	Use after-hours pushbutton to start Air Conditioning	*Room 603 booked via syllabus plus can be scheduled as normal
24A - McElwain	Level 1	Use after-hours pushbutton to start Air Conditioning	*Rooms 114, 142-144 exempt *Rooms 136-139 exempt from summer holiday scheduling only
24A - McElwain	Level 2	No Air Conditioning	*Rooms 201, 204, 209 exempt
24A - McElwain	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms 303, 304, 305, 306 exempt *Room 307, 313-316 exempt from summer holiday scheduling only
24A - McElwain	Level 4	Normal Air Conditioning	
26 - Connell	Level 1	Use after-hours pushbutton to start Air Conditioning	*Room 116 exempt
26 - Connell	Level 2	No Air Conditioning	*Gymnasiums exempt *Room 229 exempt

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
26 - Connell	Level 3	Normal Air Conditioning	
26A - Human Performance	Level 1	Use after-hours pushbutton to start Air Conditioning	*Rooms 124 to 126, 129 to 134, Comms room 136 exempt
26A - Human Performance	Level 2	No Air Conditioning	
26B - Human Movement	Level 1	Normal Air Conditioning	
26B - Human Movement	Level 2	Motion detectors will start Air Conditioning as needed	
26B - Human Movement	Level 3	Motion detectors will start Air Conditioning as needed	Rm319A is exempt and runs 24/7
26B - Human Movement	Level 4	Motion detectors will start Air Conditioning as needed	
26B - Human Movement	Level 5	Motion detectors will start Air Conditioning as needed	
32 - Gordon Greenwood	Level 1	Normal Air Conditioning	
32 - Gordon Greenwood	Level 2	Normal Air Conditioning	*Rooms 207-216 booked via syllabus plus can be scheduled as normal
32 - Gordon Greenwood	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms 308-316 booked via syllabus plus can be scheduled as normal *Rooms 319-323 exempt
32 - Gordon Greenwood	Level 4	Use after-hours pushbutton to start Air Conditioning	*Room 426, 427 exempt
32 - Gordon Greenwood	Level 5	Use after-hours pushbutton to start Air Conditioning	*Rooms 523, 527, 533 exempt
32 - Gordon Greenwood	Level 6	Use after-hours pushbutton to start Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
35 - Chamberlain	Level 1	Normal Air Conditioning	
35 - Chamberlain	Level 2	Normal Air Conditioning	*Rooms 204 and 212 exempt
35 - Chamberlain	Level 3	Use after-hours pushbutton to start Air Conditioning	
35 - Chamberlain	Level 4	Use after-hours pushbutton to start Air Conditioning	*Room 402, 406, 430 exempt
35 - Chamberlain	Level 5	Use after-hours pushbutton to start Air Conditioning	*Room 521 - 523 are exempt
37 - Joyce Ackroyd	Level 1	Use after-hours pushbutton to start Air Conditioning	*Computer Labs 115, 120 *Rooms 121, 122 and 123 are activated by motion detector
37 - Joyce Ackroyd	Level 2	Use after-hours pushbutton to start Air Conditioning	*Rooms 202, 207, 208, 209, 215, 224 and 225 are activated by motion detector
37 - Joyce Ackroyd	Level 3	Use after-hours pushbutton to start Air Conditioning	
37 - Joyce Ackroyd	Level 4	Use after-hours pushbutton to start Air Conditioning	*Rooms 403, 405 and 430 are activated by motion detector
37 - Joyce Ackroyd	Level 5	Use after-hours pushbutton to start Air Conditioning	*Rooms 515 and 520 are activated by motion detector
39 - Colin Clark	Level 1	Use after-hours pushbutton to start Air Conditioning	*Rooms 103, 105, 106 booked via syllabus plus can be scheduled as normal
39 - Colin Clark	Level 2	Use after-hours pushbutton to start Air Conditioning	*Rooms 201-204 exempt
39 - Colin Clark	Level 3	Use after-hours pushbutton to start Air Conditioning	



<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
39 - Colin Clark	Level 4	Use after-hours pushbutton to start Air Conditioning	
39 - Colin Clark	Level 5	Use after-hours pushbutton to start Air Conditioning	*Room 528 exempt
39 - Colin Clark	Level 6	Use after-hours pushbutton to start Air Conditioning	
39A - GP North	Level 1	Normal Air Conditioning	
39A - GP North	Level 2	Normal Air Conditioning	*Rooms 201, 202, 203, 208 and 209 booked via syllabus plus can be scheduled as normal
39A - GP North	Level 3	Use after-hours pushbutton to start Air Conditioning	
39A - GP North	Level 4	Use after-hours pushbutton to start Air Conditioning	
39A - GP North	Level 5	Use after-hours pushbutton to start Air Conditioning	
42 - Prentice	Level 1	Use after-hours pushbutton to start Air Conditioning	*Data Centre 101, 107, 109 exempt *Room 115 booked via syllabus plus can be scheduled as normal
42 - Prentice	Level 2	Normal Air Conditioning	*Room 212 and 216 booked via syllabus plus can be scheduled as normal
42 - Prentice	Level 3	Use after-hours pushbutton to start Air Conditioning	
42 - Prentice	Level 4	Use after-hours pushbutton to start Air Conditioning	*Rooms 405 and 413 exempt

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
42 - Prentice	Level 5	Use after-hours pushbutton to start Air Conditioning	
45 - Mansergh Shaw	Level 1	Use after-hours pushbutton to start Air Conditioning	*Rooms 104, 115 exempt *Rooms 102, 103, 105, 133, 134 exempt from summer holiday scheduling only
45 - Mansergh Shaw	Level 2	Use after-hours pushbutton to start Air Conditioning	*Room 204 booked via syllabus plus can be scheduled as normal
45 - Mansergh Shaw	Level 3	Use after-hours pushbutton to start Air Conditioning	*Server room 308 exempt
45 - Mansergh Shaw	Level 4	N/A	
45 - Mansergh Shaw	Level 5	Use after-hours pushbutton to start Air Conditioning	
47 - Axon	Level 1	No Air Conditioning	*Comms Room, Room 101A exempt
47 - Axon	Level 2	Use after-hours pushbutton to start Air Conditioning	*Room 210A exempt
47 - Axon	Level 3	Use after-hours pushbutton to start Air Conditioning	*Room 311 exempt
47 - Axon	Level 4	Use after-hours pushbutton to start Air Conditioning	
47 - Axon	Level 5	Use after-hours pushbutton to start Air Conditioning	*Rooms 501 & 514 exempt from Summer Holiday scheduling *Rooms 502-506 exempt
47A - Sir James Foots	Level 1	Normal Air Conditioning	*Room 141 booked via syllabus plus can be scheduled as normal

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
47A - Sir James Foots	Level 2	Use after-hours pushbutton to start Air Conditioning	*Rooms 241,249,250 booked via syllabus plus can be scheduled as normal *Comms room exempt
47A - Sir James Foots	Level 3	Use after-hours pushbutton to start Air Conditioning	*Room 341,351,352 booked via syllabus plus can be scheduled as normal *Comms room exempt
47A - Sir James Foots	Level 4	Use after-hours pushbutton to start Air Conditioning	*Comms room exempt
47A - Sir James Foots	Level 5	Use after-hours pushbutton to start Air Conditioning	*Rooms 570-573 are exempt
47A - Sir James Foots	Level 6	Use after-hours pushbutton to start Air Conditioning	*Comms room exempt
47A - Sir James Foots	Level 7	Use after-hours pushbutton to start Air Conditioning	*Comms room exempt
47A - Sir James Foots	Level 8	Use after-hours pushbutton to start Air Conditioning	*Comms room exempt
49 - Advanced Engineering	Level 1	Use after-hours pushbutton to start Air Conditioning	
49 - Advanced Engineering	Level 2	Use after-hours pushbutton to start Air Conditioning	*Room 239, 246, 248, 272 exempt
49 - Advanced Engineering	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms 301,316,316A are scheduled via Syllabus Plus
49 - Advanced Engineering	Level 4	Use after-hours pushbutton to start Air Conditioning	*Rooms 401,402 are scheduled via Syllabus Plus *Rooms 404 to 420 are exempt

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
49 - Advanced Engineering	Level 5	Use after-hours pushbutton to start Air Conditioning	*Rooms 502,523,526 are scheduled via Syllabus Plus *Rooms 517-525 and 530 are exempt
49 - Advanced Engineering	Level 6	Use after-hours pushbutton to start Air Conditioning	*Rooms 619 and 621 are exempt
50 - Hawken Engineering	Level 1	Use after-hours pushbutton to start Air Conditioning	*S105 only room scheduled, all other rooms exempt.
50 - Hawken Engineering	Level 2	Use after-hours pushbutton to start Air Conditioning	*Library exempt *Comms room 2A31/S213 exempt
50 - Hawken Engineering	Level 3	Use after-hours pushbutton to start Air Conditioning	*Library, rooms S311-S322 and rooms C301-C302 are exempt *Comms room 3A11/C315 exempt
50 - Hawken Engineering	Level 4	Use after-hours pushbutton to start Air Conditioning	*Library, rooms S401-S419 and rooms C402 - C407 are exempt
50 - Hawken Engineering	Level 5	Use after-hours pushbutton to start Air Conditioning	*Rooms S501, S501A-B, S506-S511 exempt
51 - Zelman Cowan	Level 1	No Air Conditioning	
51 - Zelman Cowan	Level 2	Use after-hours pushbutton to start Air Conditioning	*Comms room exempt
51 - Zelman Cowan	Level 3	Use after-hours pushbutton to start Air Conditioning	*M&A Library, training room, rooms 309-312, 317-319 are exempt
51 - Zelman Cowan	Level 4	Normal Air Conditioning	
51 - Zelman Cowan	Level 5	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only rooms 517, 504, 505 scheduled
57 - CAI	Level 1	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
57 - CAI	Level 2	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
57 - CAI	Level 3	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
57 - CAI	Level 4	Use after-hours pushbutton to start Air Conditioning	
57 - CAI	Level 5	Use after-hours pushbutton to start Air Conditioning	
60 - Gehrman	Level 1	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
60 - Gehrman	Level 2	Use after-hours pushbutton to start Air Conditioning	*Rooms 201-204A, 229, 233 exempt
60 - Gehrman	Level 3	Use after-hours pushbutton to start Air Conditioning	*Room 302, 303, 327, 328 exempt
60 - Gehrman	Level 4	Use after-hours pushbutton to start Air Conditioning	*Rooms 405, 408, 409, 433, 435 exempt
60 - Gehrman	Level 5	Normal Air Conditioning	*All rooms on this floor are exempt from holiday scheduling
60 - Gehrman	Level 6	Use after-hours pushbutton to start Air Conditioning	*Rooms 624, 630, 638-652 exempt
60 - Gehrman	Level 7	Use after-hours pushbutton to start Air Conditioning	*Rooms 701-717, 721, 727-731 exempt
60 - Gehrman	Level 8	Use after-hours pushbutton to start Air Conditioning	*Rooms 802, 803, 807, 828, 835 exempt

Building	Level	Special University Leave Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
61 - J D Story Administration	Level 1	Use after-hours pushbutton to start Air Conditioning	*Rooms 106-117 exempt *Post Office exempt from Special University leave only
61 - J D Story Administration	Level 2	Normal Air Conditioning	
61 - J D Story Administration	Level 3	Use after-hours pushbutton to start Air Conditioning	
61 - J D Story Administration	Level 4	Use after-hours pushbutton to start Air Conditioning	*L4 Comms room exempt
61 - J D Story Administration	Level 5	Use after-hours pushbutton to start Air Conditioning	
61 - J D Story Administration	Level 6	Use after-hours pushbutton to start Air Conditioning	
61 - J D Story Administration	Level 7	Use after-hours pushbutton to start Air Conditioning	*Rooms 727-740 exempt
61A - Brian Wilson Chancellery	Level 3	Use after-hours pushbutton to start Air Conditioning	
61A - Brian Wilson Chancellery	Level 4	Use after-hours pushbutton to start Air Conditioning	
61A - Brian Wilson Chancellery	Level 5	Use after-hours pushbutton to start Air Conditioning	
62 - John Hines	Level 1	N/A	
62 - John Hines	Level 2	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only office space 219-226 (excl. 221) is scheduled
62 - John Hines	Level 3	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only 324 and 331 scheduled

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
62 - John Hines	Level 4	Normal Air Conditioning	
62 - John Hines	Level 5	Normal Air Conditioning	
62 - John Hines	Level 6	Use after-hours pushbutton to start Air Conditioning	*Room 618 and 628 exempt
64 - Sir William MacGregor	Level 1	No Air Conditioning	*Most rooms exempt - only 110, 115, 117, 127, 130 scheduled
64 - Sir William MacGregor	Level 2	Normal Air Conditioning	
64 - Sir William MacGregor	Level 3	Normal Air Conditioning	
64 - Sir William MacGregor	Level 4	Normal Air Conditioning	
64 - Sir William MacGregor	Level 5	Normal Air Conditioning	*Most rooms exempt - only L5 office spaces scheduled
64 - Sir William MacGregor	Level 6	Normal Air Conditioning	Bee House
64A - Ritchie Research Labs	Level 1	Use after-hours pushbutton to start Air Conditioning	
64A - Ritchie Research Labs	Level 2	Use after-hours pushbutton to start Air Conditioning	*All of Level 2C exempt *Rooms B201-B203, A211 exempt
64A - Ritchie Research Labs	Level 3	Use after-hours pushbutton to start Air Conditioning	*All of Level 3A and 3B are exempt
64A - Ritchie Research Labs	Level 4	Use after-hours pushbutton to start Air Conditioning	*All of Level 4A and 4B are exempt
64A - Ritchie Research Labs	Level 5	Use after-hours pushbutton to start Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
65 - Skerman	Level 1	N/A	
65 - Skerman	Level 2	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - room 207 only room scheduled
65 - Skerman	Level 3	Normal Air Conditioning	
65 - Skerman	Level 4	N/A	
65 - Skerman	Level 5	Normal Air Conditioning	*Rooms 501, 509, 510, 512, 513 excluded
67 - Priestley	Level 1	Use after-hours pushbutton to start Air Conditioning	*Central Teaching rooms 141 & 142 scheduled via Syllabus Plus
67 - Priestley	Level 2	Use after-hours pushbutton to start Air Conditioning	
67 - Priestley	Level 3	No Air Conditioning	*Central Teaching rooms 342 & 343 scheduled via Syllabus Plus
67 - Priestley	Level 4	Use after-hours pushbutton to start Air Conditioning	*Central Teaching rooms 442 scheduled via Syllabus Plus
67 - Priestley	Level 5	Use after-hours pushbutton to start Air Conditioning	*Central Teaching rooms 342 & 343 scheduled via Syllabus Plus
67 - Priestley	Level 6	Use after-hours pushbutton to start Air Conditioning	*Central Teaching rooms 442 scheduled via Syllabus Plus
67 - Priestley	Level 7	Use after-hours pushbutton to start Air Conditioning	*Central Teaching rooms 442 scheduled via Syllabus Plus
68 - Chemistry	Level 01	Use after-hours pushbutton to start Air Conditioning	*Rooms 102, 102a, 103, 104, 105, 110 exempt *workshop rooms exempt
68 - Chemistry	Level 02	Use after-hours pushbutton to start Air Conditioning	*Rooms 208-213 exempt



<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
68 - Chemistry	Level 03	Use after-hours pushbutton to start Air Conditioning	
68 - Chemistry	Level 04	Use after-hours pushbutton to start Air Conditioning	*Room 417 exempt
68 - Chemistry	Level 05	Use after-hours pushbutton to start Air Conditioning	*Rooms 501, 502, 505, 508, 509 exempt
68 - Chemistry	Level 06	Normal Air Conditioning	
68 - Chemistry	Level 07	Normal Air Conditioning	
68 - Chemistry	Level 08	Normal Air Conditioning	
68 - Chemistry	Level 09	Normal Air Conditioning	
68 - Chemistry	Level 10	Normal Air Conditioning	
68 - Chemistry	Level 11	Normal Air Conditioning	
68 - Chemistry	Level 12	Normal Air Conditioning	
69 - Computer Science	Level 1	Normal Air Conditioning	
69 - Computer Science	Level 2	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only 209 scheduled
69 - Computer Science	Level 3	Use after-hours pushbutton to start Air Conditioning	*Room 327 exempt
69 - Computer Science	Level 4	Use after-hours pushbutton to start Air Conditioning	*Rooms 401, 408, 409 exempt
69 - Computer Science	Level 5	Use after-hours pushbutton to start Air Conditioning	*Room 507 exempt
69 - Computer Science	Level 6	Use after-hours pushbutton to start Air Conditioning	
69 - Computer Science	Level 7	Use after-hours pushbutton to start Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
69 - Computer Science	Level 8	Normal Air Conditioning	
72 - Cumbrae Stewart	Level 1	Use after-hours pushbutton to start Air Conditioning	
72 - Cumbrae Stewart	Level 2	Use after-hours pushbutton to start Air Conditioning	
74 - Don Nicklin	Level 1	Normal Air Conditioning	
74 - Don Nicklin	Level 2	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only room 222 scheduled
74 - Don Nicklin	Level 3	Use after-hours pushbutton to start Air Conditioning	*Rooms 321, 329, 331 exempt
75 - AIBN East	Level 1	Normal Air Conditioning	
75 - AIBN East	Level 2	Normal Air Conditioning	*Lab area exempt
75 - AIBN East	Level 3	Normal Air Conditioning	*Lab area exempt
75 - AIBN East	Level 4	Normal Air Conditioning	*Lab area exempt
75 - AIBN East	Level 5	Normal Air Conditioning	*Lab area exempt
75 - AIBN East	Level 6	Normal Air Conditioning	*Most rooms exempt - only lift corridor and offices scheduled (646-655)
75 - AIBN East	Level 7	Normal Air Conditioning	
75 - AIBN West	Level 1	Normal Air Conditioning	*Most rooms exempt - only lobby, coffee shop scheduled
75 - AIBN West	Level 2	Normal Air Conditioning	
75 - AIBN West	Level 3	Normal Air Conditioning	*Lab area exempt
75 - AIBN West	Level 4	Normal Air Conditioning	*Lab area exempt
75 - AIBN West	Level 5	Normal Air Conditioning	*Lab area exempt
75 - AIBN West	Level 6	Normal Air Conditioning	
75 - AIBN West	Level 7	Normal Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
76 - Molecular Biosciences	Level 1	Normal Air Conditioning	
76 - Molecular Biosciences	Level 2	Normal Air Conditioning	
76 - Molecular Biosciences	Level 3	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only rooms 363, 363A scheduled
76 - Molecular Biosciences	Level 4	Normal Air Conditioning	
76 - Molecular Biosciences	Level 5	Normal Air Conditioning	
76 - Molecular Biosciences	Level 6	Normal Air Conditioning	
76 - Molecular Biosciences	Level 7	Normal Air Conditioning	
78 - GP South	Level 1	Use after-hours pushbutton to start Air Conditioning	*Rooms 104, 105, 110, 112, 113 exempt
78 - GP South	Level 2	Use after-hours pushbutton to start Air Conditioning	
78 - GP South	Level 3	Use after-hours pushbutton to start Air Conditioning	
78 - GP South	Level 4	Use after-hours pushbutton to start Air Conditioning	
78 - GP South	Level 5	Use after-hours pushbutton to start Air Conditioning	*Computer room 520 is exempt *515-523 exempt from Summer Holiday
78 - GP South	Level 6	Use after-hours pushbutton to start Air Conditioning	

Building	Level	Special University Leave Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
78 - GP South	Level 7	Use after-hours pushbutton to start Air Conditioning	*Server room 742 is exempt
79 - QBI	Level 1	Normal Air Conditioning	
79 - QBI	Level 2	Normal Air Conditioning	*Most rooms exempt - only rooms 220-224, 252A, 294 scheduled
79 - QBI	Level 3	Normal Air Conditioning	*Lab area (312-327, 324A, 365-368) exempt
79 - QBI	Level 4	Normal Air Conditioning	*Lab area (408-418) exempt
79 - QBI	Level 5	Normal Air Conditioning	*Lab area (508-518) goes into relaxed weekend air conditioning mode *Microscope area (507, 592) exempt
79 - QBI	Level 6	Normal Air Conditioning	*Lab area (607-619) exempt
79 - QBI	Level 7	Normal Air Conditioning	
80 - QBP East	Level 1	Normal Air Conditioning	
80 - QBP East	Level 2	Normal Air Conditioning	*Most rooms exempt - only rooms 2130, 2124, 2131, 2143 scheduled
80 - QBP East	Level 3	Normal Air Conditioning	
80 - QBP North	Level 1	Normal Air Conditioning	*Most rooms exempt - only room 1040 scheduled
80 - QBP North	Level 2	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP North	Level 3	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP North	Level 4	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP North	Level 5	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP North	Level 6	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP North	Level 7	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP South	Level 1	Normal Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
80 - QBP South	Level 2	Normal Air Conditioning	
80 - QBP South	Level 3	Normal Air Conditioning	*Most rooms exempt - only office spaces 3312-3323 scheduled
80 - QBP South	Level 4	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP South	Level 5	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP South	Level 6	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP South	Level 7	Normal Air Conditioning	*Labs exempt - only offices scheduled
80 - QBP West	Level 1	Normal Air Conditioning	*Most rooms exempt - only rooms 1122-1126,1134, 1194, 1199 scheduled
80 - QBP West	Level 2	Normal Air Conditioning	
80 - QBP West	Level 3	Normal Air Conditioning	
80 - QBP West	Level 4	Use after-hours pushbutton to start Air Conditioning	
80 - QBP West	Level 5	Use after-hours pushbutton to start Air Conditioning	
80 - QBP West	Level 6	Use after-hours pushbutton to start Air Conditioning	
80 - QBP West	Level 7	Use after-hours pushbutton to start Air Conditioning	
81 - Otto Hirschfeld	Level 1	Normal Air Conditioning	
81 - Otto Hirschfeld	Level 2	Normal Air Conditioning	
81 - Otto Hirschfeld	Level 3	Normal Air Conditioning	
81 - Otto Hirschfeld	Level 4	Normal Air Conditioning	
81 - Otto Hirschfeld	Level 5	Normal Air Conditioning	
81 - Otto Hirschfeld	Level 6	Normal Air Conditioning	
81 - Otto Hirschfeld	Level 7	Normal Air Conditioning	

<b>Building</b>	<b>Level</b>	<b>Special University Leave</b> Until WFH direction is revised	The rooms listed below are exempt from scheduling and will run as normal during these periods
81 - Otto Hirschfeld	Level 8	Normal Air Conditioning	
82C - Seddon North	Level 1	N/A	
82C - Seddon North	Level 2	N/A	
82C - Seddon North	Level 3	No Air Conditioning	
82C - Seddon North	Level 4	No Air Conditioning	
83 - Hartley Teakle	Level 1	No Air Conditioning	*Most rooms exempt - only rooms N116, N134, N135 scheduled
83 - Hartley Teakle	Level 2	No Air Conditioning	*Most rooms exempt - only rooms C201, C203, C217 scheduled
83 - Hartley Teakle	Level 3	Use after-hours pushbutton to start Air Conditioning	*Most rooms exempt - only rooms N304-N306 and N324, N325 scheduled *Central teaching rooms C301 & C302 scheduled via Syllabus Plus
83 - Hartley Teakle	Level 4	Normal Air Conditioning	*Central teaching rooms C412, C413, C415 & C416 scheduled via Syllabus Plus
83 - Hartley Teakle	Level 5	Normal Air Conditioning	*Central teaching rooms C511, C512 & C516 scheduled via Syllabus Plus
84 - Therapies	Level 1	Use after-hours pushbutton to start Air Conditioning	
84 - Therapies	Level 2	Normal Air Conditioning	
84A - Therapies Annex	Level 1	N/A	
84A - Therapies Annex	Level 2	Use after-hours pushbutton to start Air Conditioning	*Room 207 is the only room scheduled on this level. All others normal scheduling.
84A - Therapies Annex	Level 3	Use after-hours pushbutton to start Air Conditioning	*Room 304 and comms room 331 exempt

